



The applicant: **ISINAC ACOUSTIC WORLD SL**
CALLE LOPEZ DE NEIRA 3, 3º, OFICINA 301
ES-36203 Vigo
Pontevedra

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2020AN0565



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 20AN0565

The sample reference:

“ISINAC TEX META”

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2018 is:

“B-s1,d0”

Alcoy, March 23rd 2020.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.